



Declaration of Compliance



DECLARATION

Applicant: SolarEdge Technologies LTD
 1 HaMada Street
 4673335 Herzeliya
 Israel

Product type: Backup Interface (BI)

Model:	BI-EU1P	BI-EU3P
Rating:	AC FROM GRID	
Supported grid	1 ph L-N-PE	3 ph
AC Input Current	100 A	3x63 A
AC Voltage (Nominal)	230 Vac	
AC Output Voltage Range	184-264.5 Vac	184-264.5 Vac
AC Frequency Range	50 / 60 Hz	50 / 60 Hz
	AC TO LOADS	
Nominal AC Current Output	100 A	3x63 A
AC Voltage (Nominal)	230 Vac	230 Vac
AC Output Voltage Range	184-264.5 Vac	184-264.5 Vac
AC Frequency Range	50 / 60 Hz	50 / 60 Hz

A representative test sample of above stated model passed the tests according to:

Standard: IEC 62109-1:2010
 EN 62109-1:2010

Report no: 21PP137-02

Declaration no: 23-198-00

Date of issue: 2023-05-08

Kiwa Primara GmbH
 Gewerbestraße 28
 87600 Kaufbeuren
 Germany
 Tel. +49 8341 99726-0
 primara@kiwa.com
 www.kiwa.de



Javier Jaime Solis Leon